

# National Craft Assessment and Certification Program SPECIFICATIONS

# POWER GENERATION MAINTENANCE ELECTRICIAN PGME50

January 2013

# **Focus Statement**

A Power Generation Maintenance Electrician must be able to safely use hand, power, and electrical tools, as well as electrical test equipment and PPE, according to regulatory and industry standards; interpret job specifications and industrial drawings; install, connect, troubleshoot and maintain power generation, distribution and utilization systems and components; install raceway and cable distribution systems; and install and connect transformers and troubleshoot PLCs.

#### Overview

- Two-hour closed-book examination
- May use a basic function, non-printing calculator
- No extra papers, books, notes, or study materials are allowed
- The minimum passing score is 75
- A corresponding hands-on Performance Verification is available

# **NCCER Curriculum**

All NCCER knowledge assessments are referenced to NCCER's curriculum modules as listed on this specification sheet. You may order modules from Pearson (800.922.0579) or from NCCER's Online Catalog at www.nccer.org.

# **Assessment Development**

All questions are developed and approved by subject matter experts under the direction of NCCER.

#### Credentials

Upon successful completion of the knowledge assessment, NCCER will send applicable credentials to the assessment center.

# **Score Report and Training Prescription**

Each candidate will have access to their assessment results including their overall score and recommended training.

#### **NCCER Registry**

Knowledge assessment results are recorded in NCCER's Registry and become a part of the portable record of an individual's NCCER credentials.

# **Knowledge Assessment Contents:**

Content Domain	Number of
	Questions
Conductors [40212-08, 40213-08, 40307-09]	8
Electrical Theory [40106-07, 40203-08, 40204-08, 40205-08]	12
Personnel Safety [26501-09, 40201-08, 40308-09]	10
System Maintenance [26410-08, 32401-09, 40113-07, 50401-11]	10
System Safety [26209-08, 26210-08, 26305-08, 40301-09]	9
Controls [26211-08, 40311-09, 40312-09,40409-09]	9
Power Plant Systems [40401-09, 50301-11]	6
Power Plant Equipment [40305-09,50402-11, 26406-08, 40306-09]	12
Wiring Methods and Materials [26207-08, 26409-08, 26411-08, 40103-07]	10
Motor Maintenance [26202-08, 26407-08,40304-09, 40313-09]	11
Troubleshooting [40105-07, 40303-09,26203-08, 26303-08]	5
Total Number of Questions	102



# National Craft Assessment and Certification Program S P E C I F I C A T I O N S

# **Learning Objectives related to Assessment:**

	Conductors
Registry	Module Title and Objectives:
ID	
Number:	
40212-08	Conductors & Cables
	From the cable markings, describe the insulation and jacket material, conductor size
	and type, number of conductors, temperature rating, voltage rating, and permitted
	uses.
	Determine the allowable ampacity of a conductor for a given application.
	Identify the NEC® requirements for color coding of conductors.
	Install conductors in a raceway system.
40213-08	Conductor Terminations & Splices
	Describe how to make a sound conductor termination.
	Prepare cable ends for terminations and splices and connect the ends using lugs or
	connectors.
	Describe the National Electrical Code® (NEC®) requirements for making cable
	terminations and splices.
	Demonstrate crimping techniques.
	Select the proper lug or connector for the job.
40307-09	Conductor Selection & Calculations
	Select electrical conductors for specific applications.
	Calculate and apply NEC® tap rules to a specific application.
	Size conductors for the load.
	Electrical Theory
Registry	Module Title and Objectives:
ID	
Number:	
40106-07	Craft Related Mathematics
	Use formulas to solve basic problems.
	Solve area problems.
	Solve volume problems.
	Solve circumference problems.
	Solve right triangles using the Pythagorean Theorem.
40203-08	Electric Theory
	Define voltage and identify the ways in which it can be produced.
	Explain the difference between conductors and insulators.
	Define the units of measurements that are used to measure the properties of
	electricity.
	Identify the meters used to measure voltage, current, and resistance.
	Explain the basic characteristics of series and parallel circuits.
	Use the formula for Ohm's law to calculate voltage, current, and resistance.
40204-08	Alternating Current
	Calculate the peak and effective voltage or current values for an AC waveform.
	Describe the voltage and current phase relationship in a resistive AC circuit.

	Define inductive reactance and state how it is affected by frequency.
	Define capacitive reactance and state how it is affected by frequency.
	Explain the following terms as the relate to AC circuits:
	True point
	Apparent power
	Reactive power
	Power factor
	Explain basic transformer action.
40205-08	E & I Test Equipment
	Identify and explain the purposes of test instruments commonly used to test and
	troubleshoot E & I equipment.
	Explain how to read and convert from one scale to another using the above test
	equipment.
	Explain the importance of proper meter polarity.
	Define frequency and explain the use of a frequency meter.
	Explain the difference between digital and analog meters.
	Personnel Safety
Registry ID	Module Title and Objectives:
Number:	
26501-09	Managing Electrical Hazards
	Identify types of electrical hazards and locations, and explain related safety guidelines and terms.
	Recognize and explain hazard boundaries.
	Explain employer and employee responsibilities in recognizing and managing electrical hazards.
	List common factors that lead to electrical incidents and explain the importance of using
	appropriate procedures and safe work practices.
	Analyze the electrical hazards of a given task, plan the job, and complete an electrical work
	permit request.
	Select, inspect, and maintain personal protective equipment (PPE) and test equipment used for
	electrical work.
	Explain how to create an electrically safe work condition.
40201-08	Industrial Safety for E & I
	Demonstrate safe working procedures in an industrial environment.
	Recognize electrical/energy hazards and describe how to avoid or minimize them in the
	workplace. Explain safety issues concerning lockout/tagout procedures, personal protection using assured
	grounding and isolation programs, confined space entry, respiratory protection, and fall
	protection systems.
	Recognize and apply safe working practices.
40308-09	Temporary Grounding
	Explain the purpose of temporary grounding.
	Explain requirements associated with temporary grounding devices.
	Identify and explain temporary grounding equipment.
	Explain how to install and remove temporary grounding devices.
	System Maintenance
Registry	Module Title and Objectives:
ID	
Number:	
26410-08	Motor Operation & Maintenance
	Identify motors needing replacement.
	identify motors needing replacement.

22401 00	Dravantiva & Dradiativa Maintanana
32401-09	Preventive & Predictive Maintenance
	Explain preventive and predictive maintenance.
40113-07	Lubrication
	Read and interpret a material safety data sheet (MSDS).
	Explain the EPA-hazardous waste control program.
	Explain lubricant classification.
	Explain how to select lubricants.
50401-11	Generator Maintenance
	Identify the components of AC and DC generators.
	Describe how a generator produces single-phase and three-phase AC voltage.
	Explain how AC voltage is changed to DC voltage.
	Describe the different types of connections, including:
	Delta and wye connections
	<ul> <li>Protective instrumentation (potential and current transformers)</li> </ul>
	Identify the factors that determine output voltage.
	Describe how a voltage regulator/control system operates.
	Describe the purposes and identify the major components of auxiliary systems for AC
	generators.
	Using prescribed safety precautions perform an inspection of a brush assembly and
	remove and replace a brush.
	Using prescribed safety precautions inspect a filter assembly and remove and replace a
	filter.
	interi
	System Safety
Registry	Module Title and Objectives:
ID	module fille and objectives.
Number:	Grounding & Bonding
	Grounding & Bonding  Distinguish between a short circuit and a ground fault
Number:	Distinguish between a short circuit and a ground fault.
Number:	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and
Number:	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.
Number:	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.
Number:	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC
Number:	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.
Number: 26209-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.
Number:	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses
Number: 26209-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses  Explain the necessity of overcurrent protection devices in electrical circuits.
Number: 26209-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses  Explain the necessity of overcurrent protection devices in electrical circuits.  Define the terms associated with fuses and circuit breakers.
Number: 26209-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses  Explain the necessity of overcurrent protection devices in electrical circuits.  Define the terms associated with fuses and circuit breakers.  Describe the operation of a circuit breaker.
Number: 26209-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses  Explain the necessity of overcurrent protection devices in electrical circuits.  Define the terms associated with fuses and circuit breakers.  Describe the operation of a circuit breaker.  Apply the National Electrical Code® (NEC®) requirements for overcurrent devices.
Number: 26209-08  26210-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses  Explain the necessity of overcurrent protection devices in electrical circuits.  Define the terms associated with fuses and circuit breakers.  Describe the operation of a circuit breaker.  Apply the National Electrical Code® (NEC®) requirements for overcurrent devices.  Describe the operation of single-element and time-delay fuses.
Number: 26209-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses  Explain the necessity of overcurrent protection devices in electrical circuits.  Define the terms associated with fuses and circuit breakers.  Describe the operation of a circuit breaker.  Apply the National Electrical Code® (NEC®) requirements for overcurrent devices.  Describe the operation of single-element and time-delay fuses.  Overcurrent Protection
Number: 26209-08 26210-08 26305-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses  Explain the necessity of overcurrent protection devices in electrical circuits.  Define the terms associated with fuses and circuit breakers.  Describe the operation of a circuit breaker.  Apply the National Electrical Code® (NEC®) requirements for overcurrent devices.  Describe the operation of single-element and time-delay fuses.  Overcurrent Protection  Select and size overcurrent protection for specific applications.
Number: 26209-08  26210-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses  Explain the necessity of overcurrent protection devices in electrical circuits.  Define the terms associated with fuses and circuit breakers.  Describe the operation of a circuit breaker.  Apply the National Electrical Code® (NEC®) requirements for overcurrent devices.  Describe the operation of single-element and time-delay fuses.  Overcurrent Protection  Select and size overcurrent protection for specific applications.  Hazardous Locations
Number: 26209-08 26210-08 26305-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses  Explain the necessity of overcurrent protection devices in electrical circuits.  Define the terms associated with fuses and circuit breakers.  Describe the operation of a circuit breaker.  Apply the National Electrical Code® (NEC®) requirements for overcurrent devices.  Describe the operation of single-element and time-delay fuses.  Overcurrent Protection  Select and size overcurrent protection for specific applications.  Hazardous Locations  Define the various classifications of hazardous locations.
Number: 26209-08 26210-08 26305-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses  Explain the necessity of overcurrent protection devices in electrical circuits.  Define the terms associated with fuses and circuit breakers.  Describe the operation of a circuit breaker.  Apply the National Electrical Code® (NEC®) requirements for overcurrent devices.  Describe the operation of single-element and time-delay fuses.  Overcurrent Protection  Select and size overcurrent protection for specific applications.  Hazardous Locations  Define the various classifications of hazardous locations.  Describe the wiring methods permitted for branch circuits and feeders in specific
Number: 26209-08 26210-08 26305-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses  Explain the necessity of overcurrent protection devices in electrical circuits.  Define the terms associated with fuses and circuit breakers.  Describe the operation of a circuit breaker.  Apply the National Electrical Code® (NEC®) requirements for overcurrent devices.  Describe the operation of single-element and time-delay fuses.  Overcurrent Protection  Select and size overcurrent protection for specific applications.  Hazardous Locations  Define the various classifications of hazardous locations.  Describe the wiring methods permitted for branch circuits and feeders in specific hazardous locations.
Number: 26209-08 26210-08 26305-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses  Explain the necessity of overcurrent protection devices in electrical circuits.  Define the terms associated with fuses and circuit breakers.  Describe the operation of a circuit breaker.  Apply the National Electrical Code® (NEC®) requirements for overcurrent devices.  Describe the operation of single-element and time-delay fuses.  Overcurrent Protection  Select and size overcurrent protection for specific applications.  Hazardous Locations  Define the various classifications of hazardous locations.  Describe the wiring methods permitted for branch circuits and feeders in specific
Number: 26209-08 26210-08 26305-08	Distinguish between a short circuit and a ground fault.  Define the National Electrical Code® (NEC®) requirements relating to bonding and grounding.  Distinguish between grounded systems and equipment grounding.  Use NEC Table 250.66 to size the grounding electrode conductor for various AC systems.  Explain the importance of bonding equipment in clearing ground faults in a system.  Circuit Breakers & Fuses  Explain the necessity of overcurrent protection devices in electrical circuits.  Define the terms associated with fuses and circuit breakers.  Describe the operation of a circuit breaker.  Apply the National Electrical Code® (NEC®) requirements for overcurrent devices.  Describe the operation of single-element and time-delay fuses.  Overcurrent Protection  Select and size overcurrent protection for specific applications.  Hazardous Locations  Define the various classifications of hazardous locations.  Describe the wiring methods permitted for branch circuits and feeders in specific hazardous locations.

	and fitting in an aific handous lasting
	proof fittings in specific hazardous locations.
	Control
D = =1=4	Controls
Registry	Module
ID	Title and
Number:	Objectives:
26211-08	Control Systems and Fundamental Concepts
	Describe the operating principles of contactors and relays.
	Select contactors and relays for use in specific electrical systems.
	Explain how mechanical contactors operate.
	Explain how solid-state contactors operate.
	Read wiring diagrams involving contactors and relays.
	Describe how overload relays operate.
40311-09	Hydraulic Controls
	Explain hydraulic system safety.
	Explain a hydraulic system in a process application.
40312-09	Pneumatic Controls
	Explain pneumatic system safety.
	Identify and explain pneumatic system components and symbols.
40409-09	Programmable Logic Controllers
	Describe the function and purpose of a programmable logic controller (PLC).
	Explain the general function of an input/output (I/O) module, including the following
	types:
	Discrete
	Numerical and analog data
	Special
	Remote
	Explain the power supply and ground connections to I/O modules.
	Describe the features of relay ladder logic instruction categories.
	, , ,
	Power Plant Systems
Registry	Module Title and Objectives:
ID	
Number:	
40401-09	Standby & Emergency Systems
	Describe the operating principles of an engine-driven standby AC generator.
	Recognize and describe the operating principles of both automatic and manual transfer
	switches.
	Recognize the different types of storage batteries used in emergency and standby
	systems and explain how batteries charge and discharge.
	For se3lected types of batteries, describe their characteristics, applications,
	maintenance, and testing.
	Explain normal vs. emergency sources for various applications.
50301-11	Power Plant Electrical Systems
30301-11	·
	Explain electrical power distribution associated with a power-generating facility:
	Identify how the power distribution system within a plant is configured and how it ties into the grid.
	how it ties into the grid
	Identify and describe alternate supply paths  A laternate plant drawings
	Interpret plant drawings  Find in the first time of the division of the d
	Explain the functions of mediums-voltage and low-voltage motor control centers

	(MCCs).
	Locate and identify the feeds for a power station.
	Power Plant Equipment
Registry	Module Title and Objectives:
ID	
Number:	
40305-09	Distribution Equipment
	Explain the necessity of overcurrent protection devices in electrical circuits.
	Describe the purpose of switchgear.
	Describe switchgear construction, metering layouts, wiring requirements, and
	maintenance.
	Describe the visual and mechanical inspections and electrical tests associated with low-
	voltage and medium-voltage cables, metal-enclosed busways, and metering and
	instrumentation.
	Describe a ground fault relay system and explain how to test it.
50402-11	Switchgear & Breaker Maintenance
	Describe the safety practices that must be followed when installing and maintaining
	medium-and low-voltage equipment.
	Describe and demonstrate how to safely rack out, remove, inspect, and replace low-
	voltage and medium-voltage breakers.
	Describe and demonstrate procedures for testing and maintenance of circuit breakers,
	switchgear, MCCs, and associated components.
26406-08	Specialty Transformers
	Identify three-phase transformer connections.
	Identify specialty transformer applications.
	Calculate and install overcurrent protection for specialty transformers.
	Ground specialty transformers in accordance with National Electrical Code® (NEC®)
	requirements.
40306-09	Transformer Application
	Identify three-phase transformer connections.
	Identify specialty transformer applications.
	Ground specialty transformers in accordance with National Electrical Code® (NEC®)
	requirements.
	Wiring Methods and Materials
Registry	Module Title and Objectives:
ID	
Number:	
26207-08	Cable Tray
	Select the required fittings to ensure equipment grounding continuity in cable tray
	systems.
26409-08	Heat Tracing & Freeze Protection
	Identify and describe the purpose of electric heat tracing equipment used with
	pipelines and vessels.
26411-08	Medium Voltage Terminations & Splices
	Select the proper materials and tools for medium-voltage terminations and splices.
	Prepare medium-voltage cable for terminations and splices.
	Complete cable assemblies using terminations and splices.

	Select the correct fasteners and anchors for given applications.
	Select the correct fasteriers and anchors for given applications.
	Motor Maintenance
Registry	Module Title and Objectives:
ID	Woulde True and Objectives.
Number:	
26202-08	Motors: Theory & Application
	Define the following terms:
	Duty cycle
	Full-load amps
	Interrupting rating
	Thermal protection
	NEMA-design letter
	Overcurrent
	Overload
	Power Factor
	Rated full-load speed
	Rated horsepower
	Service factor
	Explain the relationships among speed, frequency, and the number of poles in a three-
	phase induction motor.
	Explain how the direction of the three-phase motor is changed.
	Describe the methods for determining various motor connections.
26407-08	Advanced Motor Controls
	Select and install solid-state relays for specific applications in motor control circuits.
	Recognize the different types of reduced-voltage starting motor controllers and
	describe their operating principles.
	Demonstrate and/or describe the special precautions used when handling and working
	with solid-state motor controls.
	Perform preventive maintenance and troubleshooting tasks in motor control circuit.
40304-09	Motor Controls
	Indentify contactors and relays both physically and schematically and describe their
	operating principles.
	Identify pilot devices both physically and schematically and describe their operating
	principles.
	Interpret motor control wiring, connection, and ladder diagrams.
	Select and size contactors and relays for use in specific electrical motor control
	systems.
	Select and size pilot devices for use in specific electrical motor control systems.
40313-09	Motor-Operated Valves
	State safety regulations associated with motor-operated valves (MOVs).
	Explain the operating principles of various types of MOVs.
	Remove, replace, and torque a limit switch.
	Troubleshooting
Registry	Module Title and Objectives:
ID	
Number:	
40105-07	Gaskets & Packing

	Describe the use of O-rings.	
40303-09	E & I Drawings	
	Identify common types of electrical and instrumentation diagrams and drawings.	
	Read and interpret electrical diagrams used in instrumentation work:	
	Wiring diagrams	
	Ladder diagrams	
	One-line diagrams	
	Motor controller diagrams	
	Read and interpret instrumentation diagrams:	
	P&ID diagrams	
	Loop diagrams	
	Raceway diagrams	
26203-08	Electric Lighting	
	Recognize ballasts and describe their use in fluorescent and HID lighting fixtures.	
	Recognize basic occupancy sensors, photoelectric sensors, and timers used to control	
	lighting circuits and describe how each device operates.	
26303-08	Practical Applications of Lighting	
	Identify the lighting requirements associated with lighting systems used in selected applications such as office buildings, schools, theaters, hazardous areas, etc.	